625 Robert St. N. St. Paul MN 55155
P.O. Box 64975 St. Paul MN 55164 - 0975

# MINNESOTA DEPARTMENT OF HEALTH
## SECTION OF DRINKING WATER PROTECTION
### Report of Analytical Results

**Final Report - Client Copy**

The following are the results of your annual nitrate sample analysis required for compliance with federal rule, CFR 141.23.

System Name: **Westridge Lake Estates** PWSID: **1700021**

Date Collected: 5/17/2021
Date Received: 5/18/2021
Date Analyzed: 5/20/2021
Collected by: Herb Krueger
Sampling Point: COMBINED DISCHARGE

Sample #: 21E1136-01
Sample Point ID: E03

**ANALYSIS RESULTS:**

| Contaminant | Result | Maximum Contaminant Level (MCL) | Units |
|---|---|---|---|
| Nitrate + Nitrite Nitrogen, Total | .16 | 10.4 | mg/L |

**COMMENTS:**
The result(s) above show that your system is in compliance with maximum contaminant levels set by the state and federal Safe Drinking Water Rules for the contaminant analyzed. These results must be kept in your files for a minimum of ten (10) years.

If you have any questions concerning these results, call Cindy Swanson at 651/201-4656.

WATER SUPERINTENDENT
HERB KRUEGER

Date Report Generated: 5/26/2021