625 Robert St. N. St. Paul MN 55155
P.O. Box 64975 St. Paul MN 55164 - 0975

MINNESOTA DEPARTMENT OF HEALTH
SECTION OF DRINKING WATER PROTECTION
Report of Analytical Results

Final Report - Client Copy

The following are the results of your annual nitrate sample analysis required for compliance with federal rule, CFR 141.23.

System Name: **Westridge Lake Estates** PWSID: **1700021**

Date Collected: 8/5/2024 Sample #: 24H0779-01
Date Received: 8/7/2024 Sample Point ID: E03
Date Analyzed: 8/13/2024
Collected by: Herb Krueger
Sampling Point: COMBINED DISCHARGE

ANALYSIS RESULTS:

Contaminant	Result	Maximum Contaminant Level (MCL)	Units
Nitrate + Nitrite Nitrogen, Total	.2	10.4	mg/L

COMMENTS:
The result(s) above show that your system is in compliance with maximum contaminant levels set by the state and federal Safe Drinking Water Rules for the contaminant analyzed. These results must be kept in your files for a minimum of ten (10) years.

If you have any questions concerning these results, call Cindy Swanson at 651/201-4656.

WATER SUPERINTENDENT
HERB KRUEGER

Date Report Generated: 8/23/2024